

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7770-0328:010

Page 1 of 1

**CATEGORY:** Valves/Switches

**LISTEE:** Potter, 2081 Craig Rd., St. Louis MO 63146  
Contact: Brad Serangeli (800) 3245-3936 Fax (314) 878-7264

**DESIGN:** Supervisory switches listed below to monitor pressure, OS&Y, gate, globe/gate, PIV, tank temperature or water level valves. Refer to listee's data sheet for detailed product description and operational considerations.

HLS-B	WLS-W	WLS-S	PS-40A
PS-120A	OSYSU-2	OSYS-B	PMS
PTS-B	OSYSU-1	GVS	PCVS-1
PIVS-B	TTS-S	TTS-W	PCVS-2
WLS	*PTS-C		

**INSTALLATION:** In accordance with listee's printed instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation and FM or UL label.

**APPROVAL:** Listed as sprinkler system supervisory switches.

**NOTE:** Formerly 7738-0328:010

\*Rev. 05-31-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 14, 2003**

*Listing Expires **June 30, 2004***

*Authorized By:*

**DIANE K. AREND**, Senior Deputy  
Program Manager